

OFFICE USE ONLY
Log No. 89218
Permit No. _____
Basin 108
NOTICE OF INTENT NO 94050

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Ron Banta ADDRESS AT WELL LOCATION 81 West Tucker
MAILING ADDRESS _____ Yerington NV 89447

2. LOCATION SE 1/4 NE 1/4 Sec. 11 T. 13 @ NS R. 25 E. LYON County
PERMIT NO. _____ Parcel No. 09-321-14 Subdivision Name Meadow Downs Estates

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy clays		0	20	20
Hard pan		20	22	2
Sands		22	24	2
Clay Brown		24	24.5	.5
Sands		24.5	27	2.5
Clays Brown		27	30	3
Sands		30	37	7
clay		37	38	1
Sands		38	43	5
clay		43	44	1
Sands		44	57	13
Clay/Fine Sands		57	59	2
Sands		59	68	9
clay - sand		68	70	2
Med. coarse sand Brown		70	85	5
Fine sands Black		85	87	2
Med. coarse sand Brown		87	92	5
Fine sand - clay Brown		92	94	2
Sands		94	97	3
clay - fine sand		97	98	1
Big sand 1/4 - 3/8	X	98	115	17
Fine sand Black		115	117	2
Coarse sand 1/4 - 3/8	X	117	123	6
Clays - fine sand		123	126	3
Sands fine to med		126	152	26
Coarse sand 1/4 - 3/8	X	152	154	2
Sands		154	158	4
clay		158	159	1
Sand		159	160	1

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
From _____ To _____
10 5/8 Inches 0 Feet 160 Feet
_____ Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>.188</u>	<u>+2</u>	<u>160</u>

Perforations:
Type perforation mill slot
Size perforation 125 x 3' x six rows
From 138 feet to 158 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal SR Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 52 feet to 160 feet

9. WATER LEVEL
Static water level 25 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature 60 °F Quality Good/clear

Date started Aug 4 2001
Date completed Aug 27 2001

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bail	40		3 1/2
Pump	30	5'	3 1/2

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Inland Pacific Drilling Co Inc Contractor
Address Po Box 831 Yerington NV 89447 Contractor
Nevada contractor's license number issued by the State Contractor's Board 36582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1958
Signed Joel Brown
By driller performing actual drilling on site or contractor
Date Aug 30 2001