WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84222
Permit No.
Basin 87

NOTICE OF INTENT NO. 47107

1. OWNER ALVIN & PEGGY PECETTI
MAILING ADDRESS 2250 Foot Hill Road
Reno, Nevada 89511
ADDRESS AT WELL LOCATION Same

2. LOCATION SW ¼ NW ¼ Sec. 18 T. 18N N/S R. 20 E. Washoe County
PERMIT NO. (Issued by Water Resources) 040-750-08 (Parcel No.) SW Reno (Subdivision Name)

3. WORK PERFORMED
[X] New Well [X] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other ~~Mud~~

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil & Boulders		0	1	1
Brown clay with boulders and gravel		1	12	11
Granite boulder		12	16	4
Boulders & gravel with streaks of clay		16	55	39
Sand & gravel		55	68	13
Boulders & gravel with streaks of clay		68	89	21
Soft zone (NO WATER)		89	90	1
Brown clay with gravel and sand		90	129	39
Soft zone, gravel & sand	X	129	136	7
Granite boulder		136	142	6
Granite & volcanic boulders & gravel		142	155	13
Soft zone, gravel & sand	X	155	167	12
Granite & volcanic gravels and sand		167	199	32
Soft zone, gravels & sand	X	199	217	18
Black volcanic rock		217	229	12
Soft zone	X	229	235	6
Brown clay		235	239	4
Soft zone	X	239	241	2
Brown sandy clay		241	259	18
Soft zone	X	259	261	2
Brown sandy clay		261	274	13
Soft zone	X	274	275	1
Brown sandy clay		275	288	13

Date started September 14, 2001, 19
Date completed September 20, 2001, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
80+		

8. WELL CONSTRUCTION
Depth Drilled 288 Feet Depth Cased 288 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 7/8 Inches	0 Feet	288 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	288

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 128 feet to 228 feet
From 248 feet to 268 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100 feet
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 288 feet

9. WATER LEVEL
Static water level 51 feet below land surface
Artesian flow G.P.M. 80+ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [signature] (Driller performing actual drilling on site or contractor)

Date September 24, 2001

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627