

OFFICE USE ONLY
 Log No. 84223
 Permit No. _____
 Basin 179

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45797
5 Miles North of Ely

1. OWNER Gary Weaver ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS HC 32 Box 32119 _____
Ely, Nevada 89301 _____
 2. LOCATION SE 1/4 SW 1/4 Sec. 22 T. 17 N. R. 63 E. White Pine County
 PERMIT NO. Lot No. 153F APN 05-591-65 Cross Timbers
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	5	5
Course Sand & Gravel		5	20	15
Sand & Gravel		20	60	40
Sand & Small Gravel		60	75	15
Water Bearing Sand & Gravel with Clay Seams	X	75	80	5
Clay, Sand & Gravel		80	95	15
Clay with Water Bearing Sand & Gravel Stringers	X	95	98	3
Clay, Sand & Gravel		98	130	32
Clay with Water Bearing Sand & Gravel Stringers	X	130	135	5
Clay, Sand & Gravel		135	161	26

8. WELL CONSTRUCTION
 Depth Drilled 161 Feet Depth Cased 161 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10-5/8 Inches 0 Feet 161 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	161

Perforations:
 Type perforation Factory
 Size perforation 1/8" X 2" 6 Rows
 From 80 feet to 161 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50 Feet
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 161 feet

9. WATER LEVEL
 Static water level 72 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.1 °F Quality Good

Date started September 3 2001
 Date completed September 4 2001

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	45	83	1 1/2

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Avenue Contractor
Ely, Nevada 89301
 Nevada contractor's license number issued by the State Contractor's Board 14790
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
 Signed Rich Lewis By Gerald D. Christiansen
 By driller performing actual drilling on site or contractor
 Date September 5, 2001