WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84228
Permit No.
Basin 108

NOTICE OF INTENT NO. 47416

1. OWNER Harold Moore
MAILING ADDRESS

ADDRESS AT WELL LOCATION 135 Hwy 95 A N Mason Valley Yerington

2. LOCATION SE ¼ SE ¼ Sec 16 T 14 N/S R 25 E Lyon County
PERMIT NO. 67647-T (Issued by Water Resources) 14-231-12 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	2	
Sand		2	12	
Gravels Sand		12	34	
Cobbles Gravels		34	63	
Sands		63	75	
Some Clay Seams		75	85	
Sand Gravels		85	125	
Sand Clay		125	130	
Clay Gravels		130	152	
Course Sand		152	195	
Clay		195	210	
Gravels Sand		210	245	

Date started 7/17/01, 19
Date completed 7/20/01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	200+		3½ hrs
	198	7'	2 hrs
Note:	Pump Volume at max of the Pump Capability (7½ hp)		

8. WELL CONSTRUCTION
Depth Drilled 243 Feet Depth Cased 243 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¾ Inches	1 Feet	243 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	17	1.88	1	243

Perforations:
Type perforation Machine Perf
Size perforation 3/16 x 3 x 12 rows perf
From 201 feet to 242 feet
From 160 feet to 181 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 243 feet

9. WATER LEVEL
Static water level 37' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality V Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Perry Drill Inc
Contractor
Address PO 297
Contractor
SS NV 89428

Nevada contractor's license number issued by the State Contractor's Board 0051841
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1876

Signed [signature]
By driller performing actual drilling on site or contractor
Date 8/1/01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627