

OFFICE USE ONLY
 Log No. 84244
 Permit No. _____
 Basin 92A

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 47117

1. OWNER SUSAN ANGELOPOULOS ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 10640 Plata Mesa Same
Reno, Nevada 89506
 2. LOCATION SE 1/4 NW 1/4 Sec 25 T 21N N/S R 18 E Washoe County _____
 PERMIT NO. 086-161-15 Silver Knolls Subdivision Name _____
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WELL DEEPENING				
Rocks		69	70	1
Brown sandy clay		70	78	8
Blue clay		78	81	3
Brown sandy clay		81	90	9
Coarse sands	X	90	97	7
Brown sandy clay		97	105	8
Coarse sands	X	105	111	6
Brown clay		111	115	4
Medium coarse sands	X	115	122	7
Brown sandy clay		122	128	6
Soft zone		128	130	2
Blue clay		130	133	3

8. WELL CONSTRUCTION
 Depth Drilled 133 Feet Depth Cased 133 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6 Inches To 69 Feet 133 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5" OD		.188	0	133

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 89 feet to 129 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal deepening Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 70 feet to 133 feet

Date started August 16, 2001, 19____
 Date completed August 17, 2001, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18+		

9. WATER LEVEL
 Static water level 63 feet below land surface
 Artesian flow _____ G.P.M. 18+ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number 0022549
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 923
 Division of Water Resources, the on-site driller.
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date August 20, 2001