WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84381
Permit No. 67139T
Basin 215

NOTICE OF INTENT NO. 22352

1. OWNER Dry Lake Water
MAILING ADDRESS 2701 N. Tenaya Way St. 200 Las Vegas, Nevada
ADDRESS AT WELL LOCATION I-15 & Exit #58 Apex Frontage Rd - Sandia Rd

2. LOCATION NE ¼ NE ¼ Sec. 13 T. 19 N/S R. 63 E Clark County
PERMIT NO. 67139-T Issued by Water Resources
122-06-010-001 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☒ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	124'	124'
Limestone w/ intermittent fractures		124'	1800'	1676'

Date started 8-1-01, 19
Date completed 10-14-01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
250	1	24

8. WELL CONSTRUCTION
Depth Drilled 1800' Feet Depth Cased 1800' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
48 Inches		0 Feet	80 Feet
17½ Inches		80 Feet	1800 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
30"	125.64	.375	0	80
12	49.56	.375	0	1800

Perforations:
Type perforation Louvered (Roscoe Moss)
Size perforation 100 Slot
From 940 feet to 1020 feet
From 1060 feet to 1100 feet
From 1180 feet to 1320 feet
From 1400 feet to 1480 feet
From 1540 feet to 1600 feet
From 1680 to 1780

Surface Seal: ☒ Yes ☐ No
Depth of Seal 80'
Placement Method: ☒ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 1800 feet to 80' feet

9. WATER LEVEL
Static water level 654' feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature 75' °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Layne Christensen Co Contractor
Address 12030 E Riggs Rd Contractor
Chandler, Az 85249
Nevada contractor's license number issued by the State Contractor's Board 19101
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1887
Signed Lowell Stephen Clever By driller performing actual drilling on site or contractor
Date 10-24-01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627