

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. **84394**
 Permit No. _____
 Basin **162**

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **22318**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER **Alcazar**
 MAILING ADDRESS **4160 E. Bridger**
Pahrump, NV 89061
 ADDRESS AT WELL LOCATION **4160 E. Bridger**

2. LOCATION **NE 1/4 NE 1/4 Sec. 17 T 21S N/S R 54E E Nye** County
 PERMIT NO. **45-181-21** Parcel No. _____ Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown silty loam		0	6	6
brown loam	x	6	61	55
brown calciche	x	61	72	11
See next line	x	72	95	23
brown loam with calciche strings				
brown loam	x	95	140	45

8. WELL CONSTRUCTION
 Depth Drilled **140** Feet Depth Cased **140+1** Feet
 HOLE DIAMETER (BIT SIZE)
 From To
11 Inches **0** Feet **140** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
 Type perforation **sawcut**
 Size perforation **.188**
 From **120** feet to **140** feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From **50** feet to **140** feet



Date started **8/15/01** 19____
 Date completed **8/15/01** 19____

7. WELL TEST DATA
 TEST METHOD: Bailer Pump Air Lift
 Draw Down Time (Hours)
 G P M (Feet Below Static)

9. WATER LEVEL
 Static water level **59** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **cool** °F Quality **good**

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Strickland Construction Co., Inc.** Contractor
 Address **2301 Winery Road, Suite 2** Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board **40277**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller, **2086**
 Signed *[Signature]*
 By driller performing actual drilling on-site or contractor
 Date **9-26-01**

