WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84465
Permit No.
Basin 104

NOTICE OF INTENT NO. 47844

1. OWNER Lonnie Phelps
MAILING ADDRESS 1701 Koontz Lane
Carson City, NV 89701

ADDRESS AT WELL LOCATION 1701 Koontz Lane

2. LOCATION NW 1/4 SW 1/4 Sec. 28 T 15N N/S R 20E E Carson County
PERMIT NO. Issued by Water Resources
10-322-03 Parcel No.
Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
We abandoned the 6 5/8" x 165' deep well by perforating from 145'-50' using a Mills Knife and at one foot intervals at four around. We then pumped approximately 2.25 cu yards of neat cement from bottom to top using tremie pipe. We cut the top 2' off of the well from ground level.				

Date started 9/28/2001 , 19__
Date completed 9/28/2001 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	165

Perforations:
Type perforation Mills Knife
Size perforation Puncture
From 50 feet to 145 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [X] Pumped [ ] Poured

Seal Type:
[X] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 104 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 9/29/01

USE ADDITIONAL SHEETS IF NECESSARY