

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 84472
 Permit No. 48785
 Basin 29

I

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38

1. OWNER Coeur Rochester #2
 MAILING ADDRESS P.O. Box 1057
Lovelock, NV 89419

ADDRESS AT WELL LOCATION Coeur Rochester
minesite, about 12 miles northeast of Lovelock, NV

2. LOCATION NW 1/4 NE 1/4 Sec. 15 T 28N N/S R 34E E Pershing County

PERMIT NO. 48785 Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand & gravel		0	17	17
Rhyolite		17	160	143
Oxidized rhyolite		160	320	160
Fractured rhyolite		320	810	490
Fractured rhyolite with clay		810	915	105
Fractured rhyolite		915	1060	145
14" casing schedule				
Blank		+3	150	150
Mill slot		150	230	80
Louver		230	310	80
Mill slot		310	350	40
Louver		350	530	180
Mill slot		530	650	120
Louver		650	790	140
Mill slot		790	830	40
Blank		830	880	50
Mill slot		880	920	40
Louver		920	950	30
Mill slot		950	990	40
Louver		990	1020	30
Mill slot		1020	1040	20
Blank		1040	1053.4	13.400

8. WELL CONSTRUCTION
 Depth Drilled 1060 Feet Depth Cased 1052 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
36 Inches	0	12
26 Inches	12	110
19 Inches	110	1060

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
30	118.68	0.375	0	12
22	86.61	0.375	0	104.5
14	45.61	0.312	+2	1053.4

Perforations:
 Type perforation Louver, mill slot
 Size perforation 0.125", double row 0.125"

From See at left feet to _____ feet

From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 120' Neat Cement
 Cement Grout
 Placement Method: Pumped Poured Concrete Grout

Gravel Packed: Yes No
 From 120 feet to 1060 feet

9. WATER LEVEL
 Static water level 154 feet below land surface
 Artesian flow N/A G.P.M. _____ P.S.I. _____
 Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1410
 Signed John Vurgutz
 By driller performing actual drilling on-site or contractor
 Date 6/19/01

Date started 5/17/2001, 19
 Date completed 5/28/2001, 19

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)		Time (Hours)
	G.P.M.		
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>1000</u>	<u>233</u>	<u>24</u>

USE ADDITIONAL SHEETS IF NECESSARY

RECONDITIONED By LOG 126660

B.S.C.