WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84484
Permit No.
Basin 105

NOTICE OF INTENT NO. 44926

1. OWNER Elton Crowley
MAILING ADDRESS 790 Pawnee
Minden,, NV 89423

ADDRESS AT WELL LOCATION 790 Pawnee Minden Nv.
89423

2. LOCATION SE 1/4 NE 1/4 Sec. 12 T 14N N/S R 19E E Douglas County
PERMIT NO. (Issued by Water Resources) 13-080-28 (Parcel No.) Valley View (Subdivision Name)

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Set up on well clean				
out with air to 280				
ft.remove 6" liner				
from 140 to 280				
perferate casing from				
50' to 160' pump 3				
yards neat cement down				
drill pipe to bottom				
of hole filled to the				
top				

Date started 8/30/2001 , 19__
Date completed 8/31/2001 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Eddco Exploration Inc. (Contractor)
Address 7780 Curry Rd. (Contractor)
Fallon,Nv. 89406
Nevada contractor's license number issued by the State Contractor's Board 27673A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1566
Signed (By driller performing actual drilling or agent or contractor)
Date 9/22/2001

USE ADDITIONAL SHEETS IF NECESSARY