

OFFICE USE ONLY
 Log No. **84527**
 Permit No. _____
 Basin **213**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **22160**

1. OWNER **SOUTHERN CALIFORNIA EDISON** ADDRESS AT WELL LOCATION **MORAVE GENERATING STATION**
 MAILING ADDRESS **P.O. BOX 78 ROSEMAD, CA 91770** **STATION 43 BRUCE VOGELBY DR LAUREL, NV 89002**
 2. LOCATION **SW 1/4 NW 1/4 Sec. 25 T. 32 N. S. R. 66 E. CLARK** County
 PERMIT NO. **60C** **MORAVE GENERATING STATION** Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other **Drill for**
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
#60C Well Certification				
All aboveground measurements				
7" iron pipe				
6 5/8" conductor (steel)		0	10'	approx.
2" casing		0	382'	
conductor		0	20.5'	
2" casing		0	23.5'	
protective 3" balls				

8. WELL CONSTRUCTION
 Depth Drilled **420** Feet Depth Cased **420** Feet
 HOLE DIAMETER (BIT SIZE)
 From **7.58** Inches To **0** Feet **420** Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		sch 40	0	9 steel
2"		pvc sch 40	7	420

Perforations:
 Type perforation **machine**
 Size perforation **028**
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **373** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From **373** feet to **420** **1/8 to 1/4** ground feet


9. WATER LEVEL
 Static water level **83.53** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **ALLEN DRILLING INC.** Contractor
 Address **4847 S. VALLEY VIEW** Contractor
LAS VEGAS, NV 89103
 Nevada contractor's license number issued by the State Contractor's Board **18917**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1301**
 Signed **[Signature]**
 By driller performing actual drilling on site of contractor
 Date _____

Date started **August 16**, 19**2001**
 Date completed **August 16**, 19**2001**

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)



=====

WELL NUMBER: 69C

=====

WELL CONSTRUCTION SUMMARY

DATE COMPLETED: 11/06/85 DEPTH DRILLED: 420 FEET DIAMETER DRILLED: 7 5/8 INCHES
CONTRACTOR: DRILLING AND PUMPS, INC. METHOD: MUD ROTARY GEOPHYSICAL LOG: NO LITHOLOGIC LOG: YES

Casing

Interval: 0 - 5 FEET Diameter: 2 INCHES Material: STEEL
Interval: 5 - 380 FEET Diameter: 2 INCHES Material: SCH 40 PVC

Screen

Interval: 380 - 420 FEET Diameter: 2 INCHES Material: SCH 40 PVC
Slot Size: 0.02 INCH

Gravel Pack

Interval: 373 - 420 FEET Material: 1/8 TO 1/4" GRAVEL
Interval: - FEET Material:

Sanitary Seal

Interval: 0 - 373 FEET Material: CEMENT

Sounding Pipe: NONE

WELL TESTING

Test Date: Duration: HOURS Discharge: GPM
Static Water Level: FEET Drawdown: FEET Specific capacity: GPM/FT

PUMP INSTALLATION

Date Installed: 03/31/92
Manufacturer: GRUNDFOS Model: RED1-FLO 2" Meter #: INW 1025
Horsepower: Volts: Amps: Phase:
Riser Pipe Length: 122 FEET Diameter: 3/8 INCHES Material: HOSE
Intake Depth: 122 FEET Pumping Level: FEET Discharge: GPM

REFERENCE ELEVATIONS

Ground Elevation: FEET
Sounding Port Elevation: 576.29 FEET

WELL MAINTAINENCE

Redevelopment:

Equipment:

