WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84543
Permit No.
Basin 93-X

1500BC

NOTICE OF INTENT NO. 47108

1. OWNER THOMAS & LINDA GOULTER
MAILING ADDRESS 5078 So. Midland Drive
Roy, Utah 84067

ADDRESS AT WELL LOCATION Serpentine
Reno, Nevada 89506

2. LOCATION ~~NE~~ SE ¼ SE ¼ Sec. 15 T. 22N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 079-490-21 (Parcel No.) Antelope Valley Ranchettes #200 (Subdivision Name) Pcl. 2

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clays		1	3	2
Brown sand		3	11	8
Brown sandy clays		11	27	16
Granite boulder		27	28	1
Brown sandy clay		28	55	27
Soft zone, brown sand		55	57	2
Brown sandy clays		57	116	59
Weathered granite with clay streaks		116	160	44
Granite sands		160	168	8
Weathered granite with clay streaks		168	218	50
Black granite		218	235	17
Fracture granite	X	235	268	33
Black granite		268	273	5

Date started July 9, 2001, 19
Date completed July 11, 2001, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50+		

8. WELL CONSTRUCTION
Depth Drilled 273 Feet Depth Cased 273 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	50 Feet	
6 5/8 Inches	50 Feet	273 Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	273

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 225 feet to 265 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 273 feet

9. WATER LEVEL
Static water level 169 feet below land surface
Artesian flow G.P.M. 50+ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date July 12, 2001

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627