

OFFICE USE ONLY  
 Log No. 84563  
 Permit No. 87  
 Basin I  
 NOTICE OF INTENT NO. 45766

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Bob Deanna 7-11 INC. ADDRESS AT WELL LOCATION 1620 EL PANCHA BLVD  
 MAILING ADDRESS 10220 SW Greenburg Rd 470 Portland OR 97233 SPARKS NV 89431  
 2. LOCATION NE 1/4 NE 1/4 Sec. 6 T 19 N S R 20 E Washoe County  
 PERMIT NO. 026-441-35 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Asphalt</u>				<u>3"</u>
<u>TYPE 2</u>				<u>1'</u>
<u>Cobbles, Boulders</u>		<u>1'</u>	<u>25'</u>	
<u>GRAVEL, SAND</u>		<u>25'</u>	<u>35'</u>	
<u>Clay</u>	<u>36'</u>	<u>35'</u>	<u>50'</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 50' Feet Depth Cased 50' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10' Inches To 50' Feet  
 From 0 Feet To 50' Feet  
 From 0 Feet To 50' Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>		<u>5/16 40</u>	<u>0</u>	<u>50</u>

Perforations:  
 Type perforation machine slotted  
 Size perforation 0.25  
 From 35 feet to 50 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 30  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 33 feet to 50 feet

9. WATER LEVEL  
 Static water level 36 feet below land surface  
 Artesian flow NO G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality clear + g

Date started Oct 29, 01  
 Date completed Oct 29, 01

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>25 gpm</u>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Eagle Drilling Svc LLC Contractor  
 Address 7150 PLACID ST Contractor  
LAS VEGAS NV, 89119  
 Nevada contractor's license number issued by the State Contractor's Board C 51266  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2107  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date NOV 9, 01

RECEIVED  
 01 NOV 13 PM 11:46  
 STATE ENGINEERS OFFICE