

OFFICE USE ONLY  
 Log No. 87567  
 Permit No. \_\_\_\_\_  
 Basin. 87

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45266

1. OWNER Bob DENINNO 7-11 INC. ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 10220 SW GREENBURG RD #42 1620 EL RANCHO  
PORTLAND, OR 97238 SPARKS, NV 89431  
 2. LOCATION NE 1/4 NE 1/4 Sec 6 T 19 S R 20 E WASHOE County \_\_\_\_\_  
 PERMIT NO. 026-441-35 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Asphalt</u>				<u>3'</u>
<u>TYPE 2</u>				<u>1'</u>
<u>Pebbles Boulder Gavelly Sand</u>		<u>1</u>	<u>35'</u>	<u>34'</u>
<u>Play</u>	<u>34'</u>	<u>35</u>	<u>50'</u>	<u>15'</u>

8. WELL CONSTRUCTION  
 Depth Drilled 50' Feet Depth Cased 50' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10' Inches To 50' Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>		<u>sch 40</u>	<u>0</u>	<u>50</u>

 Perforations:  
 Type perforation machine slotted  
 Size perforation .020  
 From 35 feet to 50 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 30  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 33 feet to 50 feet

Date started Oct 31, 01  
 Date completed NOV 1, 01

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>2591</u>			

9. WATER LEVEL  
 Static water level 36 feet below land surface  
 Artesian flow NO G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature COOL °F Quality PLAIN

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Eagle Drilling LLC L.R.C. Contractor  
 Address 3150 PLACID STREET Contractor  
LAS VEGAS NV 89119  
 Nevada contractor's license number \_\_\_\_\_  
 issued by the State Contractor's Board C51266  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2107  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date NOV 9, 01