WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 8458
Permit No.
Basin 85

NOTICE OF INTENT NO. 46622

1. OWNER Clyde Alexander
MAILING ADDRESS 425 Decanso
Sparks, NV 89436

ADDRESS AT WELL LOCATION 425 Decanso Sprks,Nevada 89436

2. LOCATION SW 1/4 SW 1/4 Sec. 1 T 21N N/S R 20E E Washoe County
PERMIT NO. Issued by Water Resources
076-290-17 Parcel No.
Subdivision Name

3. **WORK PERFORMED**
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Hard Black Rock	x	400	640	240
T.D. 640'		640		

Date started 07/02/2001 , 19__
Date completed 07/06/2001 , 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
7	375	1 hour
15	400	1/2 hour
20	450	1/2 hour
25	500	1 hour
30	640	1 hour

8. **WELL CONSTRUCTION**
Depth Drilled 640 Feet Depth Cased 640 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6-1/8 Inches		400 Feet	640 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	6.96	.188	390	640

Perforations:
Type perforation Factory Sawed
Size perforation 1/8 x 3

From 440	feet to	450	feet
From 590	feet to	610	feet
From 630	feet to	640	feet
From	feet to		feet
From	feet to		feet

Surface Seal: [X] Yes [ ] No
Depth of Seal In Place
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. **WATER LEVEL**
Static water level 350 feet below land surface
Artesian flow G.P.M. P.S.I
Water temperature cool °F Quality good

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service
Contractor
Address P.O. Box 60130
Contractor
Reno,Nevada
Nevada contractor's license number issued by the State Contractor's Board 0035387-B
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2121
Signed Larry Welch
By driller performing actual drilling on-site or contractor
Date 07/11/2001

USE ADDITIONAL SHEETS IF NECESSARY