

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24709

1. OWNER DON HISH SMITH ADDRESS AT WELL LOCATION 821 PITTZ RD PAHRUMP NV 89041
MAILING ADDRESS 821 PITTZ RD PAHRUMP NV 89041

2. LOCATION 1/4 NE 1/4 Sec 8 T 20 S 162-10 N/S R. S3 E N7E County _____
PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Test Stock

5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>DIRT</u>		<u>0</u>	<u>45</u>	
<u>CAILICHE</u>		<u>46</u>	<u>50</u>	
<u>CLAY</u>		<u>51</u>	<u>56</u>	
<u>CLAY GRAVEL</u>		<u>57</u>	<u>72</u>	
<u>CLAY</u>		<u>73</u>	<u>80</u>	
<u>CLAY GRAVEL</u>		<u>81</u>	<u>110</u>	
<u>WATER CLAY</u>	<u>85</u>	<u>111</u>	<u>120</u>	
<u>CLAY CAILICHE</u>		<u>121</u>	<u>142</u>	

DONR/DWR
RECEIVED
NOV 15 2001
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 142 Feet Depth Cased 142 Feet

HOLE DIAMETER (BIT SIZE)
From 10 Inches To 142 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>PVC</u>	<u>SCH 40</u>	<u>0</u>	<u>142</u>

Perforations:
Type perforation SLOT
Size perforation .220

From _____ feet to _____ feet
From 142 feet to 112 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
Depth of Seal 50
Placement Method: Pumped Poured

Gravel Packed: Yes No
From 50 feet to 142 feet

Date started NOV 6 2001
Date completed NOV 6 2001

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
Static water level 53 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GATZKE DRILLING Contractor I
Address PO BOX 6628 PAHRUMP NV Contractor _____

Nevada contractor's license number issued by the State Contractor's Board 036415
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1650

Signed Jay Gatzke
By driller performing actual drilling on site or contractor
Date NOV 6 2001