WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 84681
Permit No.
Basin 212

NOTICE OF INTENT NO. 18493

1. OWNER Robert Davis
MAILING ADDRESS 318 Dunlap Rd
Orofino Idaho 83544

ADDRESS AT WELL LOCATION 1320 Las Vegas Blvd So.
Las Vegas, NV.

2. LOCATION SE ¼ NW ¼ Sec. 3 T. 21 N/S R. 61 E. Clark County
PERMIT NO. N/A Issued by Water Resources | 162-03-201-001 Parcel No. | N/A (Steinees cleaners) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Planter Fil (city) | | 0' | 2' | 2' |
| Silty gravel | | 2' | 5' | 3' |
| Caliche | | 5' | 10' | 5' |
| Fractures Caliche & gravel | 12' | 10' | 15' | 15' |

Date started 10-2-01, 19
Date completed 10-2-01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 0 Feet Depth Cased 15 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 8¼ Inches | | 0 Feet | 15 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2½ | Sch. 40 | ¼ | 0 | 5 |
| | | | | |

Perforations:
Type perforation machine slotted
Size perforation .020 in
From 5 feet to 15 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 3 to 1 bent. plug
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 15 feet to 3 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature warm °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MCCS Drilling Services (Contractor)
Address 1930 Village Center Cir Ste 3-35 (Contractor)
Las Vegas, NV
Nevada contractor's license number issued by the State Contractor's Board 47851
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2044-T1
Signed (By driller performing actual drilling on site or contractor)
Date 10-3-01

DCNR/DWR Received Nov 7 2001 Las Vegas Office

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627