WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84686
Permit No.
Basin 212

NOTICE OF INTENT NO. 22004

1. OWNER Clark County Sanitation District
MAILING ADDRESS 5857 E. Flamingo Rd. Las Vegas, NV 89122
ADDRESS AT WELL LOCATION LAS VEGAS WASH NEAR UTILITY ROAD

2. LOCATION SE ¼ SW ¼ Sec. 29 T. 21 N/S R. 63 E. CLARK County
PERMIT NO. Issued by Water Resources | 160-29-401-001 Parcel No: | MW-9 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILTY SAND		0	20	20
SAND		20	40	20
SILTY-SAND		40	50	10
SAND-		50		
VOLCANIC ROCK				
FRAGMENTS			55	5
CLAY-RICH SAND		55	60	5

DCNR/DWR
RECEIVED
NOV 16 2001
LAS VEGAS OFFICE

Date started 31 OCTOBER 2001
Date completed 31 OCTOBER 2001

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 60 Feet / Depth Cased 60 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
5½ Inches	0 Feet	60 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375		.308	0	60

Perforations:
Type perforation FACTORY SLOT PVC
Size perforation 0.020 INCH
From 45 feet to 60 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-2, 2-41 BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 41 feet to 60 feet

9. WATER LEVEL
Static water level 33.6 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 68.9 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Converse Consultants
Address 731 Pilot Rd. Suite H (Contractor)
Las Vegas, NV 89119 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 48947
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1589
Signed (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627