REPORT NO. A01.088

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 84767
PERMIT NO.
BASIN 83

NOTICE OF INTENT NO. 45635

OWNER CHARLIE CHISHOLM
MAILING ADDRESS PO BOX 9927, RENO, NV 89507

ADDRESS OF WELL 3444 PERI RANCH RD.

2. WELL LOCATION NE 1/4 SW 1/4 SEC. 15 T 19N R 21 E STOREY COUNTY

PERMIT NO _____ PARCEL NO 004-111-26 SUBDIVISION NAME RIVER DISTRICT

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [X] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
DIRT & CLAY		0	10	10
GRAY CLAY		10	13	3
GRAVELS & BROWN CLAY		13	55	42
HARD BOULDERS		55	70	15
GRAVEL & BROWN CLAY		70	80	10
GREEN & BLACK ROCK		80	140	60
GREEN & BLACK ROCK W/BROWN		140		
TRACES OF CLAY		140	225	85
BLACK RK W/BRN CLAY TRACES		225	285	60
BLACK & BROWN RK W/BROWN		285		
CLAY TRACES		285	375	90
SOFT SPOT		375	387	12
BLACK, BROWN, GREEN, RED RK		387		
WITH BROWN CLAY		387	425	38
WHITE, YELLOW, BROWN RK W/		425		
BLACK ROCK		425	435	10
GRAY CLAY, WHITE & RED ROCK		435	457	22
BLUE CLAY, BLACK ROCK		457	490	33
HEAVY BLUE GRAY CLAY		490	580	90
HEAVY GREEN & BLUE-GREY		580		
CLAY WITH FINE ROCK		580	600	20

Notes : THIS BORE HOLE HAS A SURFACE CASING AND A CAP WELDED ON IT. BORE HOLE E-LOGGED ON 07/18/01.

RECEIVED 07 MAY 14 AM 11:22 STATE ENGINEERS OFFICE

Date Started 07/10/01 Date Completed 07/18/01

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [ ] Air Develop

	GPM	DRAWDOWN	TIME (HRS)

8. WELL CONSTRUCTION

Depth Drilled 600 Depth Cased 0

HOLE DIAMETER (BIT SIZE)
8 1/2 Inches 0 Feet 600 Feet
_____ Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To

PERFORATIONS:
Type Perforation _____ Size Perforation _____
From _____ Feet to _____ Feet
From _____ Feet to _____ Feet
From _____ Feet to _____ Feet

SURFACE SEAL: [ ] Yes [ ] No
Seal Depth _____
PLACEMENT METHOD: [ ] Pumped [ ] Poured
SEAL TYPE: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout [ ] Bentonite
GRAVEL PACKED: [ ] Yes [ ] No
From _____ Feet to _____ Feet

9. WATER LEVEL

Static Water Level _____ Feet Below Land Surface
Artesian Flow _____ GPM _____ PSI
Water Temperature _____ F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name AQUA DRILLING & WELL SVC., INC.
Address 675 EDISON WAY
RENO, NV 89502

NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 1981

Signed Roger Thill
By driller performing actual drilling on site or contractor

Dated Nov. 12. 01