

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 84780
 Permit No. 55141
 Basin 61

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 47553

1. OWNER Barrick Goldstrike Mines VD97-16
 MAILING ADDRESS P.O. Box 29
Elko, NV 89803

ADDRESS AT WELL LOCATION Barrick Goldstrike
minesite, north of Carlin, NV

2. LOCATION SW 1/4 NE 1/4 Sec. 19 T 36N
 PERMIT NO. 55141 issued by Water Resources
N/A Parcel No.

N/S R 50E E Eureka County
N/A Subdivision Name

3. WORK PERFORMED
 New Well
 Replace
 Recondition
 Deepen
 Abandon
 Other

4. PROPOSED USE mining
 Domestic
 Municipal/Industrial
 Irrigation
 Monitor
 Test
 Stock

5. WELL TYPE
 Cable
 Rotary
 RVC
 Air
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Prior to abandoning well was probed with a sounder tape. Probe hung up at 65', and finally stopped at 124'. A video survey showed submersible pump power cable, starting at 48.3', and an unidentifiable obstruction at 338'. BQ tremie was run in to 338', but no amount of effort could dislodge the obstruction, which is probably the pump that hung up in the well while being pulled.				
Abandoned by pumping neat cement via tremie from 336' to surface while pouring hole plug.				
Quantities Used:				
Neat cement: 86 cu.ft.				
Hole plug: 24 cu.ft.				

8. WELL CONSTRUCTION

Depth Drilled 810 Feet Depth Cased 800 Feet
 HOLE DIAMETER (BIT SIZE)
 From 17.5 Inches To 0 Feet
9.875 Inches 20 Feet 810 Feet
 Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12.5</u>	<u>49.5</u>	<u>0.375</u>	<u>0</u>	<u>20</u>
<u>6.625</u>	<u>17.02</u>	<u>0.250</u>	<u>+2</u>	<u>800</u>

Perforations:
 Type perforation Louver
 Size perforation 0.125"
 From 118 feet to 800 feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 104'
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From 104 feet to 810 feet

9. WATER LEVEL
 Static water level 328 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1796
 Signed Ron Behreandt
 By driller performing actual drilling on-site or contractor
 Date 10/16/01

Date started 10/4/2001, 19
 Date completed 10/4/2001, 19

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.		

BST-L