

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20894

1. OWNER Roger & Jane Bohannon ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_ 6200 S. Cajon Ln.

2. LOCATION NE 1/4 NW 1/4 Sec 13 T 21-S N/S R 53 E Nye County \_\_\_\_\_  
 PERMIT NO. 44-591-07 Conestoga Country Est. Bk: 4 Lt: 21  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Brown Clay/Gran, Caliche		4	12	8
Brown Clay/Caliche		12	20	8
Gray Clay		20	68	48
Brown Clay/Caliche	X	68	110	42
Gray Clay/Caliche	X	110	130	20
Brown Clay	X	130	160	30

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12 Inches 0 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	160

Perforations:  
 Type perforation Torch Cut  
 Size perforation 1/2" width 8" long  
 From 120 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 50'  Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 160 feet

DCNR/DWR  
 RECEIVED  
 DEC 10 2001

LAS VEGAS OFFICE

9. WATER LEVEL  
 Static water level 63 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started December 4, 2001  
 Date completed December 4, 2001

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>4</u>	<u>1/4</u>

Name JIM PIKE WELL DRILLING, LLC Contractor  
 Address P.O. BOX 56 Contractor  
PAHRUMP, NV. 89041  
 Nevada contractor's license number 17563A  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1324  
 Division of Water Resources, the on-site driller  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date December 5, 2001