

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22298

1. OWNER TOM VANDEN CRITA KAY (1A) ADDRESS AT WELL LOCATION 9130 Bellestar
 MAILING ADDRESS L.V. NV Clark
 2. LOCATION SW 1/4 NE 1/4 Sec. 22 T. 22 N/S R. 60 E County
 PERMIT NO. 47489 Issued by Water Resources Parcel No. 176-22-601-002 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy Clay</u>		<u>550</u>	<u>750</u>	
<u>Sandy Clay + water</u>	<u>X</u>	<u>750</u>	<u>780</u>	
<u>Clay</u>		<u>780</u>	<u>850</u>	
<u>Sandy Clay water</u>	<u>X</u>	<u>850</u>	<u>900</u>	

8. WELL CONSTRUCTION
 Depth Drilled.....Feet Depth Cased.....Feet
 HOLE DIAMETER (BIT SIZE)
 From To
6 1/4 Inches 550 Feet 900 Feet
Inches.....Feet.....Feet
Inches.....Feet.....Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5</u>		<u>.188</u>	<u>540</u>	<u>900</u>

Perforations:
 Type perforation Factory
 Size perforation .030 Stave type
 From 840 feet to 890 feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal.....
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From.....feet to.....feet

9. WATER LEVEL
 Static water level 590 feet below land surface
 Artesian flow..... G.P.M. U.S.I.
 Water temperature.....°F Quality.....

Date started 8-25-01, 19.....
 Date completed 9-05-01, 19.....

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon H. Dimick Contractor
 Address 5360 N. Banta Vista Contractor
L.V. NV
 Nevada contractor's license number issued by the State Contractor's Board 10062
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
 Signed V.H. Dimick
 By driller performing actual drilling on site or contractor
 Date 12-10-01