

TIMET 4

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

84811

OFFICE USE ONLY

Log No. 84811  
Permit No.  
Basin. 212

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 22479

1. OWNER TIMET ADDRESS AT WELL LOCATION WATER ST. HENDERSON  
MAILING ADDRESS P.O. Box 2128  
HENDERSON NV 89009  
2. LOCATION NW 1/4 SW 1/4 Sec 6 T 22 N/S R 63 E Clark County  
PERMIT NO. 179-06-301-004 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>BROWN SILTY SAND</u>				
<u>W/ GRAVEL</u>		<u>0</u>	<u>27.5</u>	<u>27.5</u>
<u>BROWN SILTY CLAYEY</u>				
<u>GRAVEL W/ SAND</u>		<u>27.5</u>	<u>39.</u>	<u>11.5</u>
<u>BROWN-GRAY FAT</u>				
<u>CLAY W/ SAND</u>		<u>39</u>	<u>40</u>	<u>1.</u>

8. WELL CONSTRUCTION  
Depth Drilled 0 Feet Depth Cased 40 Feet  
HOLE DIAMETER (BIT SIZE)  
From 10 Inches To 40 Feet  
Inches Feet Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>		<u>sch 40</u>	<u>0</u>	<u>25</u>

Perforations:  
Type perforation MACHINE  
Size perforation .020  
From 25 feet to 40 feet  
From feet to feet  
From feet to feet  
From feet to feet  
From feet to feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 21  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 23 feet to 40 feet

9. WATER LEVEL  
Static water level 28.0' feet below land surface  
Artesian flow G.P.M. P.S.I.  
Water temperature °F Quality

Date started 9-27-01, 19...  
Date completed 9-27-01, 19...

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name ETALE DRILLING LLC Contractor  
Address 7150 PLACID  
LAS VEGAS NV 89119 Contractor  
Nevada contractor's license number 51266  
issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2107  
Signed Anthony Huerto  
By driller performing actual drilling on site or contractor  
Date 10-11-01

