WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 84814
Permit No.
Basin 212

NOTICE OF INTENT NO. 18490

1. OWNER E & S Center
MAILING ADDRESS 3275 S Jones Suite 105
Las Vegas, NV

ADDRESS AT WELL LOCATION 2201 East Sahara (Burger King)
Las Vegas, NV

2. LOCATION NW ¼ NW ¼ Sec. 12 T. 21 N/S R. 61 E/W CLARK County
PERMIT NO. N/A (Issued by Water Resources) 162-01-401-009 (Parcel No.) Parcel Map File 42 Pg. 15 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Fill (Type II) | | 0' | 2' | 2' |
| Silty gravel (mostly silt) | 17' | 2' | 25' | 23' |

Date started 10-4-01, 19
Date completed 10-4-01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 0 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 8¼ Inches | | 0 Feet | 25 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2½ | Sch 40 | ¼ | 0 | 10 |

Perforations:
Type perforation machine slotted
Size perforation 020 in
From 10 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 8-6 Bent. plug
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 8 feet to 25 feet

9. WATER LEVEL
Static water level 17 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature cold °F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MCCS (Contractor)
Address 1930 Village Center Cir Ste 3-382 (Contractor)
Las Vegas, NV
Nevada contractor's license number issued by the State Contractor's Board 47851
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2044-T1
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10-5-01

DCNR/DWR Received OCT 18 2001 Las Vegas Office

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627