

6 WELLS

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

OFFICE USE ONLY  
Log No. 84828  
Permit No.  
Basin 212

NOTICE OF INTENT NO. 22704  
2875 E CHARLESTON AVE

1. OWNER LOWES HIW INC  
MAILING ADDRESS 1530 FARADAY AVE #140  
CARLSBAD CA 92008  
ADDRESS AT WELL LOCATION LAS VEGAS NV  
2. LOCATION NW 1/4 NE 1/4 Sec. 1 T. 21 N/S R. 61 E. CLARK County  
PERMIT NO. 162-01-102-003 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Asphalt</u>		<u>0</u>	<u>3'</u>	<u>3"</u>
<u>Type II</u>		<u>3'</u>	<u>1'</u>	<u>9"</u>
<u>Blown Sandy Clay</u>		<u>1'</u>	<u>12'</u>	<u>11'</u>
<u>Grey Clay</u>		<u>12.50</u>	<u>15.50</u>	<u>3.50</u>

STEMPorary WELLS  
Got WATER Sample AND  
ABANDONED WITHIN TWO DAYS

DATE 08-13-2001  
TIME 27 PM 1:26

8. WELL CONSTRUCTION  
Depth Drilled 15.50 Feet Depth Cased 15.50 Feet  
HOLE DIAMETER (BIT SIZE)  
From To  
8" Inches 0 Feet 15.50 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2 1/2"</u>		<u>Sch. 40</u>	<u>0</u>	<u>15.50</u>

Perforations:  
Type perforation Factory  
Size perforation .020  
From 15.0 feet to 10.0 feet  
From feet to feet  
From feet to feet  
From feet to feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal \_\_\_\_\_  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 15.50 feet to 8.0 feet

9. WATER LEVEL  
Static water level 12.50 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M.  
Water temperature Cool °F Quality Palatable

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name EAGLE Drilling LLC Contractor  
Address 7150 PLACID RD  
LAS VEGAS NV 89119 Contractor  
Nevada contractor's license number 51266  
issued by the State Contractor's Board.  
Nevada driller's license number issued by the M 2173  
Division of Water Resources, the on-site driller.  
Signed Wells Dugas  
By driller performing actual drilling on site or contractor  
Date 8/14/01

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			