

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22501

1. OWNER BROADBENT & ASSOCIATES ADDRESS AT WELL LOCATION 5700 PARADISE ROAD LV. NV
 MAILING ADDRESS 8 WEST PACIFIC AVE HENDERSON NV 89015

2. LOCATION NE 1/4 SW 1/4 Sec 27 T 21 S 002 N/S R 61 E CLARK County
 PERMIT NO. 102-200-102-27-202 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>ASPHALT</u>		<u>0</u>	<u>2"</u>	<u>2"</u>
<u>TYPE II</u>		<u>2"</u>	<u>3'</u>	<u>2'10"</u>
<u>SILT-SAND</u>		<u>3'</u>	<u>10'</u>	<u>7'</u>
<u>CALICHE</u>		<u>10"</u>	<u>16'</u>	<u>6'</u>
<u>SILTY CLAY</u>		<u>16"</u>	<u>19'</u>	<u>3'</u>
<u>CALICHE</u>		<u>19'</u>	<u>21'</u>	<u>2'</u>
<u>SILTY CLAY</u>		<u>21'</u>	<u>23'</u>	<u>2'</u>
<u>CLAY BROWN</u>		<u>23'</u>	<u>27'</u>	<u>4'</u>
<u>28 VAPOR EXTRACTION WELLS</u>				

8. WELL CONSTRUCTION
 Depth Drilled: 28.5 Feet Depth Cased: 28.5 Feet

HOLE DIAMETER (BIT SIZE)
 From 18 Inches To 28.0 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>		<u>SCH 40</u>	<u>0</u>	<u>28.0</u>

Perforations:
 Type perforation: MACHINE
 Size perforation: .050

From 12 feet to 27 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal: 28'
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 10' feet to 27 feet

Date started: JULY - 9TH 2001
 Date completed: AUG - 8 2001

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level: _____ feet below land surface
 Artesian flow: _____ G.P.M. _____ P.S.I.
 Water temperature: _____ °F Quality: _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name: ENGLE DRILLING LLC Contractor
 Address: 7150 PINEHURST RD LAS VEGAS NV 89119 Contractor
 Nevada contractor's license number issued by the State Contractor's Board: 51266
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 102107
 Signed: [Signature] By driller performing actual drilling on site or contractor
 Date: 10/11/01