

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 894942
 Permit No. 101
 Basin 101
 NOTICE OF INTENT NO. 46875

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER JAY LANNON ADDRESS AT WELL LOCATION 1205 ERNEST
 MAILING ADDRESS _____
 2. LOCATION SW 1/4 SW 1/4 Sec. 30 T. 19 N. R. 29 E Churchill County
 PERMIT NO. 007-831-01 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>CLAY</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>SAND</u>		<u>10</u>	<u>45</u>	<u>35</u>
<u>Black clay</u>		<u>45</u>	<u>75</u>	<u>40</u>
<u>Black sand</u>		<u>85</u>	<u>125</u>	<u>40</u>
<u>Clay</u>		<u>125</u>	<u>135</u>	<u>10</u>
<u>SAND</u>		<u>135</u>	<u>145</u>	<u>10</u>

RECEIVED
 01 SEP 11 AM 11:08
 STATE ENGINEERING OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 145 Feet Depth Cased 145 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
12 Inches 0 Feet 145 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>3.2</u>	<u>.280</u>	<u>0</u>	<u>145</u>

Perforations:
 Type perforation SHOTS
 Size perforation 7/8 x 3
 From 140 feet to 145 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 140 feet to 145 feet

9. WATER LEVEL
 Static water level 13 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality unknown

Date started 7-7-2001
 Date completed 7-8-2001

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>10</u>	<u>4</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name FARRELL DRILLING Contractor
 Address P.O. Box 5205 Contractor
Fallen, NV 89407
 Nevada contractor's license number issued by the State Contractor's Board 43145
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2082
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 7-30-01