WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84946
Permit No.
Basin 89

NOTICE OF INTENT NO. 46625

1. OWNER Mike Dobson
MAILING ADDRESS 150 Jackdaw
Carson City, NV 89704

ADDRESS AT WELL LOCATION 150 Jackdaw Carson City,Nevada 89704

2. LOCATION SW 1/4 SW 1/4 Sec. 32 T 17N N/S R 20E E Washoe County
PERMIT NO. Issued by Water Resources
050-411-05 Parcel No.
New Washoe City Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Pull on casing,will not come,waive perforating per Tom Gallager State Water Resources,Cut off casing 4 feet below finished grade,Install 2 trimie pipe to depth of 75 feet pump approx 5500 Lbs of neat cement to abandon well. Total Depth - 78 feet				

Date started 09/05/2001 , 19__
Date completed 09/06/2001 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Dry			

8. WELL CONSTRUCTION
Depth Drilled 78 Feet Depth Cased 78 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
Inches	Inches	Feet	Feet
Inches	Inches	Feet	Feet
Inches	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	10.4	.156	-4	78

Perforations:
Type perforation Inplace
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal none
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level Dry feet below land surface
Artesian flow G.P.M. P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service Contractor
Address P.O. Box 60130 Contractor
Reno,Nevada 89506
Nevada contractor's license number issued by the State Contractor's Board 35387-B
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509
Signed Larry Welch
by driller performing actual drilling on-site or contractor
Date 09/06/2001

USE ADDITIONAL SHEETS IF NECESSARY