WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84995
Permit No.
Basin 03

NOTICE OF INTENT NO. 42070

1. OWNER Loyd Elliott
MAILING ADDRESS
ADDRESS AT WELL LOCATION 415 San Clemens Dayton, NV

2. LOCATION NW ¼ SE ¼ Sec. 30 T. 17 N/S R. 22 E. Lyon County
PERMIT NO. Issued by Water Resources
003-263-11 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| DIRT/ROCK | | 0 | 65 | 65 |
| SANDY BROWN CLAY | | 65 | 110 | 45 |
| FRACTURED ROCK | | 110 | 210 | 110 |
| FINE GRAVEL | X | 210 | 250 | 40 |
| FINE GRAVEL-SANDY CLAY | | 250 | 275 | 25 |

Date started 12 Sep 01, 19
Date completed 15 Sep 01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 25+ | | 1.5 |

8. WELL CONSTRUCTION
Depth Drilled 275 Feet Depth Cased 275 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 9 7/8 Inches | 0 Feet | 275 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | .188 | +1 | 275 |
| | | | | |

Perforations:
Type perforation Factory milled
Size perforation 3/32" X 3"
From 235 feet to 275 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60ft
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 275 feet

9. WATER LEVEL
Static water level 190 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality CLEAR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Blain Drilling & Pump Co. (Contractor)
Address P.O. Box 1[illegible] Carson City, NV 89702 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 46498
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
Signed Jack Dotson (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627