

OFFICE USE ONLY
 Log No. 85211
 Permit No. _____
 Basin 93
 NOTICE OF INTENT NO. 47713

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

11 AAC

1. OWNER ARLUS HOLLER ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2955 Antelope Valley Road 3735 Antelope Valley Road
Reno, Nevada 89506 Reno, Nevada 89506
 2. LOCATION NE 1/4 15 11 T. 22N N/S R. 19 E. Washoe County
 PERMIT NO. 079-500-2453 Antelope Valley Red Rock Estates #262 Subdivision Name
 Issued by Water Resources Parcel No. par. 3

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay with decomposed granite mixed		1	18	17
Brown fine sand		18	21	3
Brown clay with decomposed granite mixed		21	44	23
Rusty brown decomposed granite		44	47	3
Brown sandy clays		47	99	52
Brown sand		99	111	12
Weathered granite		111	145	34
Gray granite		145	240	95
Weathered granite		240	269	29
Fracture granite	X	269	291	22
Weathered granite		291	297	6

8. WELL CONSTRUCTION
 Depth Drilled 297 Feet Depth Cased 297 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 50 Feet
8 5/8 Inches 50 Feet 297 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>0</u>	<u>297</u>

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 257 feet to 297 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 297 feet

9. WATER LEVEL
 Static water level 102 feet below land surface
 Artesian flow _____ G.P.M. 15 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date October 31, 2001

Date started October 26, 2001, 19____
 Date completed October 30, 2001, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>15</u>		