WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85352
Permit No.
Basin 106

NOTICE OF INTENT NO. 45726

1. OWNER Charles Malone
MAILING ADDRESS PO Box 831 Carson City, Nev 89702
ADDRESS AT WELL LOCATION 3642 Quail Run Wellington, Nv 89444

2. LOCATION S 1/2 1/4 S E 1/4 Sec. 16 T. 10 N/S R 22 E Douglas County
PERMIT NO. Issued by Water Resources | Parcel No. 1023-16-002-099 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand + D.G.		0	5	5
Sand + River Rock		5	10	5
Brown Sand + Gravel		10	40	30
Brown Clay		40	42	2
Boulders		42	50	8
Brown Sand + Gravel		50	80	30
Brown Clay		80	85	5
Brown Sand + Gravel		85	125	40
Broken Green Brown	✓	125	140	15
White Rock				

Date started NOV 5, 2001, 19
Date completed NOV 7, 2001, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	120	2 HRS

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 140 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	140

Perforations:
Type perforation FACTORY
Size perforation [illegible]
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 30
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 140 feet to 50 feet

9. WATER LEVEL
Static water level 32 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nevada Pump & Drilling Contractor
Address P.O. Box 2227 Dayton, NV 89403 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0046357
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2187
Signed Thomas Evans
By driller performing actual drilling on site or contractor
Date NOV. 20, 2001

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627