

OFFICE USE ONLY
 Log No. 5589
 Permit No. 109
 Basin. 19047

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19047

1. OWNER Albert S. Bozisk Jr ADDRESS AT WELL LOCATION: Beckie Creek Ranch on Hwy 130y Road
 MAILING ADDRESS: 34 Rivers Rd Smith NV 89430 No physical number
 2. LOCATION: N 1/4, N 24, T 6N, R 27E, Mineral County
 PERMIT NO. 007-020-20 Parcel No. NA Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|------------------|--------------|------|----|-----------|
| Sand and Gravel | | 0 | | 20 |
| Rocks and clay | | 20 | | 40 |
| Sand and Gravel | | 40 | | 60 |
| Rocks and Clay | | 60 | | 80 |
| Clay and Rocks | Yes | 60 | | 80 |
| Clay and Gravel | Yes | 80 | | 100 |
| Clay and Gravel | Yes | 100 | | 120 |
| Clay and Rocks | Yes | 120 | | 160 |
| Clay and Gravel | Yes | 160 | | 180 |
| Rocks and Gravel | Yes | 180 | | 210 |

8. WELL CONSTRUCTION
 Depth Drilled 210 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10" To 200 Feet
 Casing Schedule

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 1/2"</u> | | <u>Certahooks</u> | <u>110</u> | <u>200</u> |
| | | <u>Heavy wall</u> | | |
| | | <u>PVC</u> | | |

 Perforations:
 Type perforation Slot
 Size perforation 1/32"
 From 100 feet to 200 feet
 Surface Seal: Yes No Depth of Seal 50'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No From 350' feet to 200 feet
 9. WATER LEVEL
 Static water level 60' feet below land surface
 Artesian flow NA G.P.M. NA P.S.I.
 Water temperature Cold °F Quality Good

Date started 10-15 2001
 Date completed 10-31 2001

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|-----------|-------------------------------|--------------|
| <u>20</u> | <u>6 FT.</u> | <u>1 hr.</u> |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Charles Branning Contractor
 Address Box 264 Miner, NV 89422
 Nevada contractor's license number issued by the State Contractor's Board Owner Builder
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1332
 Signed Charles E Branning
 By driller performing actual drilling on site or contractor
 Date 11-2-001