

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 85534  
 Permit No. \_\_\_\_\_  
 Basin 1612  
 NOTICE OF INTENT NO. 22332

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Kral ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 5380 N. Cline 5380 N. Cline  
Pahrump, NV 89048  
 2. LOCATION NW 1/4 SE 1/4 Sec. 16 T 19S N/S R 53 E Nye County  
 PERMIT NO. 29-261-07 Country Place II  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE  
 New Well  Replace  Recondition  Domestic  Irrigation  Test  Cable  Rotary  RVC  
 Deepen  Abandon  Other  Municipal/Industrial  Monitor  Stock  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
See next line		0	8	8
brown loam with caleche strings				
brown loam with rock		8	85	26
brown loam with gravel	x	85	125	40
See next line	x	125	200	75
brown loam with gravel and rock				

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200+1 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
11 Inches 0 Feet 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	200

 Perforations:  
 Type perforation sawcut  
 Size perforation .188  
 From 180 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 200 feet  
 9. WATER LEVEL  
 Static water level 120 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality good

DCNR/DWR  
 RECEIVED  
 JAN 04 2002  
 LAS VEGAS OFFICE

Date started 11/3/01, 19\_\_\_\_  
 Date completed 11/3/01, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Strickland Construction Co., Inc. Contractor  
 Address 5801 S. Homestead Contractor  
Pahrump, NV 89048  
 Nevada contractor's license number issued by the State Contractor's Board 40277  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086  
 Signed [Signature] By driller performing actual drilling on-site or contractor  
 Date 11.22.01