Faxed 4/28/02 687-6972

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86032
Permit No.
Basin 108

NOTICE OF INTENT NO. 44562 [redacted]

1. OWNER Compstons, (Del Porto) Moreda Diary, Hills
MAILING ADDRESS
ADDRESS AT WELL LOCATION Hwy 95A North #155 Yerington, NV

2. LOCATION SE ¼ SE ¼ Sec. 9 T. 14 N/S R. 25 E. Lyon County
PERMIT NO. (19838-5920) (19839-6063) 19840 5950 Issued by Water Resources
14-191-09 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dirt & Sand		0'	3'	
Sand & Silt		3'	15'	
Cobbles & Sand		15'	30'	
Boulders & Sand		30'	41'	
Cobbles & Sand	✓	41'	55'	
Brown Clay		55	75'	
Course Sand & Clay		75'	104'	
Gravel, Sand, Silt	✓	104	110'	
Brown Clay		110'	115'	
Boulders & Clay		115'	120'	
Gravel & Sand	✓	120'	185'	
Clay & Gravel		185'	280'	
Cobbles, Gravel, Sand	✓	280'	405'	
Blue Green Clay		405'	415'	
Cobbles, Gravel, Sand	✓	415'	450'	
Boulders, Cobbles, Gravel	✓	450'	476'	
Gray Clay & Gravel	✓	476	502'	

Date started April, 1/02, 19
Date completed April, 8/02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
2500	From 500 feet,	
10 Hrs.		

8. WELL CONSTRUCTION
Depth Drilled 502' Feet Depth Cased 502' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
25' Inches	0 Feet	502' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16"	43 lbs	.250	+1	502'

Perforations:
Type perforation Sawed 64 Slots per Foot.
Size perforation 1/8 x 3"
From feet to feet
From 160' feet to 200' feet
From feet to feet
From 240' feet to 502' feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50' feet to 502' feet

9. WATER LEVEL
Static water level 60' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc
Contractor
Address Po Box 599
Contractor
Silver Springs NV. 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed Nathaniel L Leach
By driller performing actual drilling on site or contractor
Date April 27/02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627