

OFFICE USE ONLY
Log No. 86037
Permit No. 68217
Basin R30
Pg 1 of 2

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23426
Windjammer road
Amargosa, NV

1. OWNER Rockview Dairies ADDRESS AT WELL LOCATION
MAILING ADDRESS Mecca and Windjammer road
Amargosa, NV
2. LOCATION NW 1/4 SW 1/4 Sec. 9 T. 17 N/S R. 49 E Nye County
PERMIT NO. 68217 19-381-07 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
cemented rock + gravel		0	25	
lg. gravel w/ clay + sandstone		25	40	
rock w/ gravel		40	75	
rock w/ clay		75	90	
sandstone w/ rock		90	100	
sandy clay		100	115	
clay		115	135	
sandstone		135	145	
clay		145	155	
rock + clay		155	165	
sandstone w/ Quartz		165	180	
clay		180	205	
sandy clay		205	215	
scap gravel + clay		115	225	
millstone w/ clay		225	245	
broken clay		245	330	
orange clay + millstone		330	340	
broken clay		340	375	
brown + white clay		375	385	
white clay		385	405	
gray + brown clay		405	415	
gray clay		415	425	
chaly clay + sandstone		425	435	
clay + hard clay		435	445	
sandstone + clay		445	455	
white clay + millstone		455	465	
clay + sandstone		465	485	
white clay		485	495	
clay		495	505	

8. WELL CONSTRUCTION
Depth Drilled 570 Feet Depth Cased 570 Feet
HOLE DIAMETER (BIT SIZE)
From 0 To 570 Feet
22 Inches 0 Feet 570 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14		.250	+1.5	570

Perforations:
Type perforation Screen = .0100 opening
Size perforation Possible Saw Cut = 3/16" x 3"
From 80 feet to 120 feet Screen
From 120 feet to 200 feet Perf
From 200 feet to 260 feet Perf
From 260 feet to 570 feet Perf

Surface Seal: Yes No Seal Type:
Depth of Seal 50 feet Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 570 feet

9. WATER LEVEL
Static water level 102 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Warm °F Quality Good

Date started 3-31-02 2002
Date completed 4-4-02 2002

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name American Prillingard pump service Contractor
Address 3040 Callahan Street Contractor
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 0020578
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2208
Signed Owen Brinkerhoff
By driller performing actual drilling on site or contractor
Date 4-14-02

