

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 86038  
 Permit No. 67986  
 Basin 230  
 NOTICE OF INTENT NO. 23422

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

1. OWNER Ed Goodheart ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS Mecca Road  
Americassi, NV 89020  
 2. LOCATION NW 1/4 NE 1/4 Sec 16 T 16S N/S R 48 E Nye County  
 PERMIT NO. 67986 Issued by Water Resources Parcel No. 19-031-13 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<del>Gravel</del>		0	45	
Cemented rock & gravel		40	50	
Hard Brown Clay		50	65	
Gravel		65	100	
Gravel w/s Sandstone		100	125	
Sandy Clay w/s sandstone		125	140	
Gravel w/s Sandstone		140	155	
Sandstone & Sand		155	165	
Gravel & sandstone		165	175	
Sand		175	185	
Clean gravel		185	195	
Sandstone		195	205	
Clay & Gravel		205	215	
Clean sand & gravel		215	245	
Clean sand & sandstone		245	255	
sand w/ particles of Clay		255	265	
Clay w/s gravel		265	275	
Clean gravel		275	285	
Clean gravel & Rock		285	295	
Clean gravel		295	305	
Clean gravel & Rock		305	315	
Clean gravel		315	325	
Clean gravel & Rock		325	335	
Clean gravel		335	375	
Gravel w/ little Clay		375	385	
Gravel & Rock		385	395	
Cemented rock & gravel		395	405	

8. WELL CONSTRUCTION  
 Depth Drilled 405 Feet Depth Cased 405 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 24 Inches 0 Feet 405 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14		.250	+1	405

Perforations:  
 Type perforation S&W Cat 3/16" x 3" Double  
 Size perforation 3/16" x 3"  
 From 80 feet to 405 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 54  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 54 feet to 405 feet

9. WATER LEVEL  
 Static water level 107 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Coal °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name American Drilling & Pump Service Contractor  
 Address 3040 Callahan Street Contractor  
Winnemucca, NV 89445  
 Nevada contractor's license number issued by the State Contractor's Board 0020578  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2208  
 Signed Owen Brunkhardt  
 By driller performing actual drilling on site or contractor  
 Date 4-14-02

Date started 4-10 2002  
 Date completed 4-12 1902

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			