WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86108
Permit No.
Basin 101

NOTICE OF INTENT NO. 47544

1. OWNER Frank Woolsey
MAILING ADDRESS 2161 W Williams Avenue PMB 280
Fallon, NV 89406

ADDRESS AT WELL LOCATION 1072 Robin Drive,
Fallon, NV 89406

2. LOCATION SE 1/4 SE 1/4 Sec. 21 T 19N N/S R 28E E Churchill County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Brown Sand		3	12	9
Brown Clay		12	20	8
Brown Sand		20	35	15
Brown Clay		35	37	2
Brown Sand		37	43	6
Gray Sand		43	50	7
Black Sand		50	54	4
Gray Sand		54	58	4
Gray Clay		58	59	1
Brown Clay		59	61	2
Brownish Sand		61	62	1
Brown Sand	XX	62	66	4

RECEIVED 02 JAN 30 AM 11:07 STATE ENGINEER'S OFFICE

Date started 11/20/2001, 19__
Date completed 11/20/2001, 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1hr

8. **WELL CONSTRUCTION**
Depth Drilled 66 Feet Depth Cased 66 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	66	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.96	.188	0	10
6 PVC	3.92	.258	10	66

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 63 feet to 66 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 60
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 60 feet to 66 feet

9. **WATER LEVEL**
Static water level 13 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1264 (Contractor)
Fallon Nv. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753-T1
Signed Norman Parsons (By driller performing actual drilling on-site or contractor)
Date 01/02/2002

USE ADDITIONAL SHEETS IF NECESSARY