WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86118
Permit No.
Basin 103

NOTICE OF INTENT NO. 45907

1. OWNER Clay Neely
MAILING ADDRESS 2615 N.E. Anna Ave. Hillsboro, Or 97124-2499
ADDRESS AT WELL LOCATION 3253 Highland Wy Gardnerville NV 89410

2. LOCATION S 1/2 SW 1/4 Sec. 13 T. 10 N/S R. 22 E. Douglas County
PERMIT NO. N/A (Issued by Water Resources) 37-502-04 (Parcel No.) Holbrook Highlands (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand + Rock		0	10	10
Brown Sand, DG, Gravel		10	125	125
Brown Clay		125	146	21
Broken Black + Grey Rock		146	200	54
Brown Clay		200	225	25
Broken Black, Brown		225	250	25
Red Green Rock	X			

Date started 1-10-02, 19
Date completed 1-16-02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		3

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)
From To
10 5/8 Inches 0 Feet 250 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	280

Perforations:
Type perforation FACTORY
Size perforation
From 250 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 180 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nevada Pump + Drilling (Contractor)
Address PO Box 2227 (Contractor)
Dayton NV 89403
Nevada contractor's license number issued by the State Contractor's Board 0046357
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 3157
Signed Thomas Evans
By driller performing actual drilling on site or contractor
Date 1-20-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627