COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86123
Permit No.
Basin 105

NOTICE OF INTENT NO. 46410

1. OWNER DAVE DEWITT
MAILING ADDRESS 2601 BOWERS LN
GARDNERVILLE, NV 89410

ADDRESS AT WELL LOCATION 2601 BOWERS LN
GHARDNERVILLE, NV 89410

2. LOCATION SW ¼ SW ¼ Sec 10 T 12 N R 21 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) | Parcel No. 1221-10-000-006 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	3	3
GRAVELS		3	78	75
CLAY & SMALL SANDS		78	115	37
GRAVELS		115	118	3
LOST CIRCULATION		118	120	2
SWITCHED TO AIR				
COURSE GRAVELS	XXX	120	190	70
VERY HARD AND				
FRACTURED GRAVELS				

RECEIVED 02 MAY 16 AM 8:44 STATE ENGINEER'S OFFICE

Date started 4/26, 20 02
Date completed 5/02, 20 02

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	30	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	190 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	190

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 170 feet to 190 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 190 feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow G.P.M ~~25~~ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature] By driller performing actual drilling on site or contractor
Date 5/08/02

(Rev 3-91) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429