

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 86128  
 Permit No. \_\_\_\_\_  
 Basin 102

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 47282

1. OWNER B. W. R. Kuebler ADDRESS AT WELL LOCATION 1715 Deer St. Silver Springs, NV  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SW 1/4 NE 1/4 Sec. 30 T. 30 N. R. 17 E. 25 Hygon County  
 PERMIT NO. 17-444-12 Parcel No. \_\_\_\_\_ Subdivision Name Riverside Sub # 1 Lot 520  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MICA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Sand</u>		<u>0</u>	<u>76</u>	
<u>Coarse Clay Sand</u>		<u>76</u>	<u>115</u>	
<u>Sand Gravel</u>		<u>115</u>	<u>139</u>	
<u>Coarse Sand</u>				
<u>Sand Gravel</u>		<u>139</u>	<u>162</u>	
<u>Coarse Clay</u>		<u>162</u>	<u>164</u>	
<u>Coarse Sand</u>		<u>164</u>	<u>200</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)  
 From 0 Inches To 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>1.575</u>	<u>130.00</u>	<u>3/16</u>	<u>+1</u>	<u>70</u>
<u>1.675</u>	<u>3.00</u>	<u>5/8</u>	<u>70</u>	

Perforations:  
 Type perforation Scallop Sand  
 Size perforation 1 1/4" V 5/16" 8 Rows  
 From 100 feet to 100 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 0-50  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

Date started 2-12-2007  
 Date completed 2-13-2007

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
<u>50 GPM</u>			<input checked="" type="checkbox"/>
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL  
 Static water level: 45 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Reed Drilling Inc  
 Address PO Box 599 Silver Springs NV 89429  
 Nevada contractor's license number 00318741  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources: the on-site driller 00187  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 2-14-07