

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 80154  
 Permit No. \_\_\_\_\_  
 Basin 101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **48267**

1. OWNER Frank Woolsey  
 MAILING ADDRESS 2161 W Williams Ave #260  
Fallon, NV 89406

ADDRESS AT WELL LOCATION 4172 Pelican Drive,  
Fallon, NV 89406

2. LOCATION SW 1/4 NE 1/4 Sec. 28 T 19N N/S R 28E E Churchill County

PERMIT NO. \_\_\_\_\_ Issued by Water Resources | not available Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	10	10
Brown Clay		10	18	8
Brown Sand		18	27	9
Brown Clay		27	32	5
Brown Sand		32	40	8
Gray Clay		40	43	3
Brown Sand		43	45	2
Gray Sand		45	50	5
Gay Clay		50	52	2
Gray Sand		52	54	2
Gray Clay		54	58	4
Brown Sand	XX	58	63	5

8. WELL CONSTRUCTION  
 Depth Drilled 63 Feet Depth Cased 63 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 63 Feet  
 Inches Feet Feet Feet  
 Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	10
6 PVC	3.92	.258	10	63

Perforations:  
 Type perforation saw cut  
 Size perforation 1/8

From 59 feet to 62 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 55  Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 55 feet to 63 feet

9. WATER LEVEL  
 Static water level 10 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality unknown

Date started 02/05/2002, 19  
 Date completed 02/05/2002, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>		<u>1 hr</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. Contractor  
 Address P.O. Box 1265 Contractor  
Fallon Nv. 89407

Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753-T1

Signed Norman Parsons  
 By driller performing actual drilling on-site or contractor

Date 02/06/2002