

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 86172
 Permit No. 67735
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 47360

1. OWNER Bing Materials ADDRESS AT WELL LOCATION Kimmerling Road-Minden
 MAILING ADDRESS P.O. Box 487
Minden, NV 89432

2. LOCATION SW 1/4 SW 1/4 Sec. 16 T 12N N/S R 20E E Douglas County
 PERMIT NO. 67735 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand/gravel/cobbles		0	97	
sand/gravel/hard rocks	x	97	110	13
sand/gravel & boulders	x	110	136	26
sand/gravel & sm.	x	136		
cobbles			152	16
sand/gravel/boulders	x	152	154	2
sand/gravel w/cobbles	x	154	204	50
sand & gravel w/boulders	x	204	219	15
sand & gravel w/cobbles	x	219	229	10
sand & gravel w/boulders	x	229	238	9
sand & gravel w/cobbles	x	238	259	21
sand & gravel w/boulders	x	259	269	10
sand & gravel w/cobbles	x	269	278	9
clay		278	281	3
sand & gravel w/cobbles	x	281	290	9
clay		290	293	3
sand & gravel	x	293	299	6
sand & gravel w/little		299		
clay			302	3
clay		302	313	11
sand & gravel	x	313	318	5
clay		318	336	18

8. WELL CONSTRUCTION
 Depth Drilled 336 Feet Depth Cased 310 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
36 inches 0 Feet 50 Feet
28 inches 50 Feet 336 Feet
 _____ inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
30		corrugated	0	50
16		.250	0	80
16		.250	300	310

Perforations:
 Type perforation Quad row
 Size perforation .100 slot
 From 80 feet to 300 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 _____
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 0 feet to 336 feet

9. WATER LEVEL
 Static water level 42 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

Date started 12/17/01, 19____
 Date completed 12/19/01, 19____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc.
 Contractor
 Address 4675 W. Winnemucca Blvd
 Contractor
Winnemucca, Nevada 89445
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1572
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 1/5/02

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
P/L 175.3	1550	133.3	10 hrs.