

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 86245  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 47250

1. OWNER Donald R. Leverty ADDRESS AT WELL LOCATION 1758 Foothill Road  
 MAILING ADDRESS P.O. Box 439 Gardnerville, Nv.  
Genoa, NV 89411 New ARN 1319-27-000-002

2. LOCATION SE NW 1/4 NE NW 1/4 Sec. 27 T 13N N/S R 19E E Douglas County  
 PERMIT NO. 17-180-30 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soil and granite boulders	no	0	7	7
dg and granite boulders	no	7	22	15
dg granite	no	22	116	94
dg with gray clay	no	116	207	91
Hard fractured granite with gray clay in the fractures	no	207	379	172
Hard Fractured granite with light colored clay in fractures	yes	379	460	81

8. WELL CONSTRUCTION  
 Depth Drilled 460 Feet Depth Cased 460 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0	120
9 7/8 Inches	120	280
8 3/4 Inches	280	460

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+2	460

Perforations:  
 Type perforation Factory Milled  
 Size perforation 1/8X3 6 row

From	<u>240</u>	feet to	<u>260</u>	feet
From	<u>380</u>	feet to	<u>400</u>	feet
From	<u>440</u>	feet to	<u>460</u>	feet
From		feet to		feet
From		feet to		feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100ft.  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 100 feet to 460 feet

9. WATER LEVEL  
 Static water level 48ft feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Eddco Exploration Inc. Contractor  
 Address 7780 Curry Contractor  
Fallon, Nv. 89406  
 Nevada contractor's license number issued by the State Contractor's Board 27673A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586  
 Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date 3/3/2002

Date started 2/4/2002, 19\_\_\_\_  
 Date completed 2/27/2002, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:	
	Bailer	Pump
<input checked="" type="checkbox"/> Air Lift	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>35</u>		<u>2hrs</u>