WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86262
Permit No. 63203
Basin 84

NOTICE OF INTENT NO. 47375

1. OWNER Western Turf
MAILING ADDRESS P.O. Box 20065
Reno, NV 89515

ADDRESS AT WELL LOCATION 5200 ~~Grass Valley~~ Rd
Palomino Valley,
Reno

2. LOCATION NW 1/4 NE 1/4 Sec. 8 T 22N N/S R 21E E Washoe County
PERMIT NO. 63203 Issued by Water Resources
077-~~200-04~~ 080-13 Parcel No.
Palomino V. Unit 1 Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ABANDONMENT				
Perforated well from 95		0		
ft to surface			95	95
Pumped (15 cy) 32,430		0		
lbs of neat cement from				
270 ft. to surface			270	270
Plugging of log # 16438				

RECEIVED 02 APR -5 AM 11:39 STATE ENGINEER'S OFFICE

Date started 3/22/02 , 19__
Date completed 3/22/02 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14		.250	0	270

Perforations:
Type perforation mill slot
Size perforation 1/8 x 3
From 95 feet to 265 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 96 ft. feet below land surface
Artesian flow ____ G.P.M. P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. Contractor
Address 4675 W. Winnemucca Blvd Contractor
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2177

Signed [signature] By driller performing actual drilling on-site or contractor

Date 4/4/02