COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86303
Permit No.
Basin 105

NOTICE OF INTENT NO. 42043

1. OWNER JOHNSON DEVELOPMENT
MAILING ADDRESS P.O. BOX 1848
GARDNERVILLE, NV 89410

ADDRESS AT WELL LOCATION 1846 CHESTNUT CT
GARDNERVILLE, NV 89410

2. LOCATION NW ¼ NW ¼ Sec 24 T 12 N R 20 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) | 1220-24-302-015 (Parcel No.) | RHUENSTROTH AREA (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	3	3
BOULDER AND COBBLES		3	47	44
LARGE GRAVELS		47	130	83
GRAVELS AND CLAY SEAMS		130	150	20
FRACTURED OBSIDIAN GRAVELS	XXX	150	180	30

RECEIVED 02 APR 17 AM 9:28 STATE ENGINEER'S OFFICE

Date started 3/28, 20 02
Date completed 3/31, 20 02

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	40	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	180 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	180

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 180 feet

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M ~~25~~ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed [signature] By driller performing actual drilling on site or contractor
Date 3/27/02

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429