

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 42041

1. OWNER BLANE McGUIRE Const. ADDRESS AT WELL LOCATION 1915 WISEMAN
Gardnerville NV 89410
 MAILING ADDRESS 1915 WISEMAN
2110 LAKE SHORE DR. CARSON CITY 89703
 2. LOCATION NE 1/4 NE 1/4 Sec. 25 T. 12 S. R. 20 E. Douglas County
 PERMIT NO. 1220-25-501-017 Parcel No. _____ Subdivision Name Rhensstrath Area
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>OVERBURDEN</u>		<u>1</u>	<u>8</u>	<u>8</u>
<u>LARGE GRAVELS</u>		<u>8</u>	<u>80</u>	<u>70</u>
<u>BROWN CLAY/SM GRAVEL</u>		<u>80</u>	<u>100</u>	<u>20</u>
<u>SM GRAVELS / FRACTURE</u>		<u>100</u>	<u>160</u>	<u>60</u>
<u>SM GRAVELS / COLORED</u>	XXXXX	<u>160</u>	<u>220</u>	<u>60</u>

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet
 HOLE DIAMETER (BIT SIZE)
 From 1 1/4 Inches To 0 Feet 220 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>220</u>

Perforations:
 Type perforation MILL SLOT
 Size perforation 3 X 3/32
 From 200 feet to 220 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 220 50 feet to 220 feet

9. WATER LEVEL
 Static water level 80 ft feet below land surface
 Artesian flow _____ G.P.M. 30 P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 3-2 2002
 Date completed 3-5 2002

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR LIFT</u>	<u>30 GPM</u>	<u>40 ft</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name (MIKE HACK) CAPITAL CITY WELL Contractor
 Address 20 KIT KAT DR Contractor
CARSON CITY NV. 89706
 Nevada contractor's license number 41775
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 2157
 Division of Water Resources, the on-site driller.
 Signed Ad Crane
 By driller performing actual drilling on site or contractor
 Date 3-6-02