

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48327

1. OWNER Eugene Lepire ADDRESS AT WELL LOCATION 7513 Center Dr Carson City, Nev 89701
 MAILING ADDRESS P.O. Box 2811 Carson City, Nev 89702 COUNTY Carson
 2. LOCATION S.W. 1/4 SE 1/4 Sec. 5 T. 14 S. R. 20 E
 PERMIT NO. 9-311-57 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND + D.G.		0	10	10
BROWN CLAY		10	15	5
BROWN SAND + D.G.		15	79	64
GREY CLAY		79	85	6
GREY SAND		85	110	25
BLEND OF GREY CLAY		110	113	3
BROWN SAND + GRAVEL		113	120	7
BROWN GREY BLACK		120	180	60
GREEN SAND + GRAVEL				

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet
 HOLE DIAMETER (BIT SIZE)
108 Inches From 0 Feet 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>108</u>		<u>.188</u>	<u>0</u>	<u>180</u>

Perforations:
 Type perforation FACTORY
 Size perforation _____
 From 160 feet to 180 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 100' Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 180 feet to 100 feet

9. WATER LEVEL
 Static water level 25 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started 2-1-2002, 19_____
 Date completed 2-5-2002, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40+</u>		<u>2 HRS.</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **NEVADA PUMP & DRILLING**
 Address P.O. BOX 2227 DAYTON, NV 89403
 Nevada contractor's license number issued by the State Contractor's Board 090357
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2187
 Signed Thomas Evans
 By driller performing actual drilling on site or contractor
 Date 2-6-02