COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86324
Permit No.
Basin 105

NOTICE OF INTENT NO. 46387

1. OWNER LARRY PARRETTA
MAILING ADDRESS 1475 KELLY PARK CIR.
MORGAN HILL , CA 95037

ADDRESS AT WELL LOCATION 2010 PALOMINO LN
GARDNERVILLE , NV 89410

2. LOCATION NW ¼ SW ¼ Sec 19 T 12 N R 21 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) | Parcel No. 1221-19-002-002 | Subdivision Name RHUENSTROTH AREA

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	3	3
HARDPAN CLAY		3	6	3
COURSE GRAVELS		6	76	70
COURSE GRAVELS		76	148	72
BROWN CLAY		148	210	62
GUMMY CLAY		210	235	25
FRACTURED GRAVELS VERY FRACTURED OBSIDIAN GRAVELS	XXX	235	280	45

Date started 1/04 , 20 02
Date completed 1/06 , 20 02

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	45	2.5 HRS

8. WELL CONSTRUCTION

Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	100 Feet
9 7/8 Inches	100 Feet	280 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	280

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 260 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 55 ☒ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 55 feet to 280 feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow G.P.M 25 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY , NV 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack
By driller performing actual drilling on site or contractor
Date 2/08/02