WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 56-337
Permit No.
Basin 105

NOTICE OF INTENT NO. 48330

1. OWNER Nancy L. Downey
MAILING ADDRESS P.O. Box 19136
Las Vegas Nev 89132

ADDRESS AT WELL LOCATION 2299 Meadowlark Ln
Genoa, Nev 89411

2. LOCATION SE ¼ NE ¼ Sec. 10 T. 13 N/S R. 19 E/W Douglas County
PERMIT NO. (Issued by Water Resources) 1319-10-610-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand + Clay		0	3	3
Brown Clay		3	10	7
Sand + Gravel		10	28	18
Grey Clay		28	34	6
Grey Sand + Rock		34	70	36
Grey Sandy Clay		70	72	2
Grey Sand + Gravel		72	90	18
Brown Clay + Sand		90	99	9
Black + Brown Sand + Rock		99	110	11
Black + Brown + Grey Rock		110	130	20
Brown + Grey Sand		130	150	20
Brown Clay + Sand		150	165	15
Black + Brown Sand + Gravel		165	180	15
Brown Clay		180	200	20
Brown Clay + Sand		200	230	30
Brown + Black + Brown		230	270	40
Green + White Rock				

Date started 2-7-02, 19
Date completed 2-14-02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50		4 hrs.

8. WELL CONSTRUCTION
Depth Drilled 270 Feet Depth Cased 270 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	270 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		Sch. 80	10	270
6 5/8		.188	0	10 Thread Lock

Perforations:
Type perforation Factory
Size perforation .032
From 230 feet to 270 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 270 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow Yes G.P.M. 10 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name NEVADA PUMP & DRILLING (Contractor)
Address P.O. BOX 2227 (Contractor)
DAYTON, NV 89403

Nevada contractor's license number issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157

Signed Thomas Evans
By driller performing actual drilling on site or contractor

Date 2-28-02

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627