

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45718

1. OWNER Cathy Adamson ADDRESS AT WELL LOCATION 2536 Fremont  
 MAILING ADDRESS 2536 Fremont Minden, NV 89423  
 LOCATION SW 1/4 NW 1/4 Sec 02 T. 13 N/S R. 20 E DeWitt County  
 PERMIT NO. 1320 02001-022 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy Bc Clay</u>		<u>128</u>	<u>160</u>	
<u>Bc Clay</u>		<u>160</u>	<u>175</u>	
<u>Sandy Bc Clay</u>		<u>175</u>	<u>195</u>	
<u>Bc Clay</u>		<u>195</u>	<u>207</u>	
<u>Large Sand Small</u>	<u>✓</u>	<u>207</u>	<u>225</u>	
<u>Gravel</u>				
<u>Small Sand</u>		<u>225</u>	<u>230</u>	

8. WELL CONSTRUCTION 230  
 Depth Drilled 102 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>1.58</u>	<u>13</u>	<u>0.10</u>	<u>120</u>	<u>210</u> <u>230</u>

Perforations:  
 Type perforation 1 1/2" x 1 1/2"  
 Size perforation \_\_\_\_\_  
 From 210 feet to 230 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 113 feet below land surface  
 Artesian flow 115 G.P.M. P.S.I.  
 Water temperature 60 °F Quality 115

Date started 10-13-01  
 Date completed 10-14-01

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>4.157</u>	<u>200</u>	<u>4 1/2</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

**NEVADA PUMP & DRILLING**  
 Name \_\_\_\_\_  
 Address P.O. BOX 2227  
DAYTON, NV 89403

Nevada contractor's license number 0046357  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the 2187  
 Division of Water Resources, the on-site driller.

Signed Marty Lopez  
 By driller performing actual drilling on site or contractor  
 Date 10-20-01